

ВЕДОМОСТЬ ПОТРЕБЛЕНИЯ ЭЛЕКТРИЧЕСКОЙ МОЩНОСТИ ЗА ЗАМЕРНЫЙ ДЕНЬ
20. Декабря 2017г.

К Указанию № _____ от _____ 2008г.

ПС (Наименование потребителя)
Салют 110/6/6 Кв

Наименование присоедин.	Точка замера/текущая фиксация присоединения	Контролируемый параметр	Единица измерения	Время замера																								Примечание	
				0.00	1.00	2.00	3.00	4.00	5.00	6.00	7.00	8.00	9.00	10.00	11.00	12.00	13.00	14.00	15.00	16.00	17.00	18.00	19.00	20.00	21.00	22.00	23.00		24.00
1сш 6 кВ		U	кВ	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3
				6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3
				6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3
				6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3
2сш 6 кВ		U	кВ	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3
				6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	
				6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	
				6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	
4сш 6 кВ		U	кВ	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3
				6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	
				6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	
				6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	
С1Т рч. 39	1сш 6 кВ	P	МВт	3.0240	2.9688	2.9856	3.3408	3.4392	3.5544	3.8952	4.3992	4.6008	4.5672	4.4760	4.0920	4.3824	4.2912	4.3128	4.0224	3.8160	3.3304	3.7728	3.6394	3.5184	3.3480	3.1920	3.1368	3.0880	
				0.8712	0.8448	0.9312	0.9312	0.9168	0.9792	1.1640	1.5288	1.6080	1.6032	1.5384	1.2744	1.5800	1.5456	1.4784	1.2984	1.1832	1.1136	1.0512	1.0104	1.0008	0.9168	0.8544	0.8880		
				298.2	292.5	296.4	328.6	337.3	349.4	385.2	441.3	461.8	458.7	448.5	406.1	440.8	432.2	432	400.5	378.6	378	371.1	357.8	346.6	328.9	313.1	308.9		
				0.288	0.285	0.312	0.279	0.267	0.275	0.299	0.348	0.35	0.351	0.344	0.311	0.356	0.36	0.343	0.323	0.31	0.291	0.279	0.274	0.268	0.283	0.283	0.283		
С1Т рч. 50	2сш 6 кВ	P	МВт	2.1600	2.0736	2.0472	1.9992	2.1000	2.2716	3.7080	4.4040	4.6848	4.7486	4.7280	3.8760	4.7856	4.7160	4.1664	3.5856	3.6024	3.5832	3.5448	3.4512	3.4368	3.1440	2.7408	2.5248	2.4680	
				0.6384	0.6312	0.6168	0.6168	0.6024	0.8256	1.1976	1.5600	1.5936	1.6200	1.5940	1.2936	1.6008	1.5768	1.4256	0.9408	0.9312	0.9192	0.8856	0.8688	0.9168	0.8784	0.7944	0.7680		
				213.4	205.4	202.6	198.3	207	269.5	369.2	442.7	468.9	475.5	472.5	387.2	478.2	471.2	417.3	351.3	352.6	350.5	346.2	337.2	337.1	309.3	270.4	250.1		
				0.296	0.304	0.301	0.309	0.287	0.303	0.323	0.354	0.34	0.341	0.335	0.334	0.335	0.334	0.342	0.282	0.258	0.257	0.25	0.252	0.267	0.279	0.29	0.304		
С2Т рч. 5	3сш 6 кВ	cosφ	МВт	0.959	0.957	0.956	0.961	0.957	0.952	0.943	0.947	0.946	0.948	0.949	0.948	0.946	0.948	0.946	0.947	0.946	0.948	0.946	0.947	0.947	0.966	0.963	0.96	0.957	
				3.1488	3.1344	3.1560	3.1488	3.1608	3.4464	4.3008	5.4648	5.2920	5.4240	5.2896	4.4208	5.0496	5.0016	5.1792	4.7952	4.3920	4.0800	3.9888	3.8592	3.7848	3.6240	3.4272	3.3504		
				1.6272	1.6440	1.6464	1.6392	1.5840	1.6320	2.1648	2.8632	2.9486	2.9688	2.9640	2.1552	2.8848	2.9136	2.7884	2.2776	2.0592	2.0640	1.9440	1.8624	1.8216	1.7832	1.7928			
				335.9	335.4	337.3	336.4	335	361.3	456.3	584.6	574.1	585.9	561.2	466	551.1	548.5	557.8	503	459.7	433.3	420.5	404.5	399.7	384.4	366.1	360.1		
С2Т рч. 16	4сш 6 кВ	cosφ	МВт	0.888	0.886	0.887	0.887	0.887	0.894	0.904	0.893	0.883	0.877	0.893	0.899	0.886	0.884	0.88	0.903	0.895	0.892	0.889	0.904	0.893	0.887	0.887	0.882		
				0.9744	0.4080	1.0560	1.0224	1.0128	0.9744	1.0872	1.4304	1.4808	1.5072	1.4256	1.5528	1.5144	1.6816	1.3632	1.3440	1.3968	1.2656	1.2812	1.2984	1.2456	1.1880	1.1256	1.0560		
				0.4032	0.4272	0.4200	0.4200	0.4080	0.4080	0.4512	0.6288	0.6072	0.6096	0.6072	0.5184	0.6384	0.6576	0.5616	0.5088	0.4968	0.4056	0.3864	0.3816	0.3816	0.3888	0.3960	0.4056		
				99.93	55.98	107.7	104.7	103.5	100.1	111.5	148.1	151.7	154.1	146.8	155.1	155.7	171.1	139.7	136.2	140.5	126.3	127.7	128.2	123.4	164.1	113.1	107.2		
Положение РПН-110 С2Т — 10 ступень		I	А	99.93	1.047	0.398	0.411	0.403	0.419	0.415	0.44	0.41	0.404	0.426	0.334	0.422	0.391	0.412	0.379	0.356	0.319	0.289	0.294	0.306	0.23	0.352	0.384		
				0.924	0.691	0.929	0.925	0.928	0.922	0.924	0.915	0.925	0.927	0.92	0.949	0.921	0.931	0.925	0.935	0.942	0.953	0.958	0.959	0.956	0.974	0.943	0.934		
Положение РПН-110 С1Т — 9 ступень		cosφ																											

Первый зам. Генерального
директора — технический
Директор

Е.А. Крылов

Главный энергетик

В.И. Харьковский

